



GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
APPROVAL FOR CHANGE OF NAME OF THE ESTABLISHMENT



From
The District fire officer,
Yadadri Bhongir Division.

To,
P SUCHITHRA,
Suvali Estate Campus,
Nalgonda Road,
Bhongir Town & Mandal,
Yadadri Bhuvanagiri District,

Ack. No. 431540002022 Dated: 11/03/2022

Sir,

Sub:

TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE
DEPARTMENT —Yadadri Bhongir Division.
Application for change of name of the Establishment **NEW
DIMENSIONS INTERNATIONAL SCHOOL** in Sy.No. **H.NO.2-
5-Na0002, SUVALI ESTATE CAMPUS, NALGONDA ROAD,
BHONGIR TOWN & MANDAL, YADADRI BHUVANAGIRI
DIST** situated at **Buvanagiri Village, Bhongir Mandal, Yadadri
District-Permission accorded for change of name in our official
Correspondences Regd.**



Ref:

1. Online Application Acknowledgement No 431540002022
 2. This office NOC for Occupancy with Re. No. 325320002020 ✓
 3. Sworn in Affidavit in support of rightful authority of the Applicant dt. 11/03/2022 ✓
- *****

1) Vide reference 2nd cited, the existing/proposed Multi Storeyed Building/Non Multi Storeyed Building **NEW DIMENSIONS INTERNATIONAL SCHOOL** located in Sy. No. **H.NO.2-5-Na0002, SUVALI ESTATE CAMPUS, NALGONDA ROAD, BHONGIR TOWN & MANDAL, YADADRI BHUVANAGIRI DIST** situated at **Buvanagiri Village Bhongir Mandal, Yadadri District** was issued Occupancy NOC for **Ground, 1 Floors,** floors with a height of **7.40** meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy.

2) Vide reference 1st cited, the builder/owner of the above said establishment stated that he is the authorized person on behalf of it and requested to change the name of that establishment in our official correspondences. He also submitted the documental evidences of the change of name of the establishment were in online.

3) In view of the above and based on the documental evidences submitted by the applicant , the request for name Change of the above establishment as **NEW DIMENSION (EM) HIGH SCHOOL** located in Sy. No. **H.NO.2-5-Na0002, SUVALI ESTATE CAMPUS, NALGONDA ROAD, BHONGIR TOWN & MANDAL, YADADRI BHUVANAGIRI DIST** situated at **Buvanagiri Village, Bhongir Mandal, Yadadri District** with a height of **7.40 Meters** for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy is here by permitted in all our official correspondences henceforth. All the terms and conditions and other data mentioned in Occupancy NOC remain unchanged.

4) This document does not confer any legal right for claiming titleship of property or Conversion of land use/Occupancy or Building Regularization.

Yours Sincerely,
District fire officer,
Yadadri Bhongir Division.

Copies to:

- i) The Management
- ii) Multistoried Building Inspection Committee

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"



GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE



From
The Director General
State Disaster Response and Fire Services,
Telangana, Hyderabad.

To,
P SUCHITRA,
H.NO.2-5-Na0002,
SUVALI ESTATE CAMPUS,
NALGONDA ROAD,
BHONGIR TOWN & MANDAL,
YADADRI BHUVANAGIRI DIST,

Rec. No.325320002020 Dated:01/03/2020

Sir,

Sub:

TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT -.

Issue of No Objection Certificate for Occupancy to the Non Multi storeyed Building of NEW DIMENSIONS INTERNATIONAL SCHOOL, H.NO.2-5-Na0002, SUVALI ESTATE CAMPUS, NALGONDA ROAD, BHONGIR TOWN & MANDAL, YADADRI BHUVANAGIRI DIST/-Buvanagiri/Bhongir/Yadadri, Hyderabad - Regarding.



Ref:

1. Acknowledgement No325320002020dt.01/03/2020
2. Inspection Committee Report, Acknowledgement No: 325320002020

1. The Multi Storeyed Building Inspection committee, vide reference cited (2) have inspected the Non Multi Storeyed Building of NEW DIMENSIONS INTERNATIONAL SCHOOL, H.NO.2-5-Na0002, SUVALI ESTATE CAMPUS, NALGONDA ROAD, BHONGIR TOWN & MANDAL, YADADRI BHUVANAGIRI DIST/-Buvanagiri/Bhongir/Yadadri and submitted the following report.

2. The above building was constructed without obtaining the Provisional Noc from this department and now the builder submitted application for issuance of No Objection Certificate for occupancy to the existing building of Ground, 1 Floors, with a height of 7.40 Meters for EDUCATIONAL B-1 Schools up to senior secondary level.

3. Open Spaces : The builder provided the following open spaces all around the building.

Sl.N	side	Open space Required as per Supreme Court's order on W.P.No.483 of 2004	Open space Provided
0		2004	
1	North	6.00	7.50
2	South	6.00	10.00
3	East	6.00	10.00
4	West	6.00	6.30
5	Front Direction	East	

4. Means of Access :

Sl. No	Gate Width As per NBC 2016	Required	Provided
1	Entry gate width	6.00	6.0
2	Exit Gate Width	6.00	6.0
3	Entry Gate Head Clearance	4.50	5.0
4	Exit Gate Head Clearance	4.50	5.00

5. Travel Distance

Sl. No.	Item / Description	Required (Not More than in Mtrs.)	Provided
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	29.51
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	1.00

6. Stair Cases (As per NBC 2016)

Sl.no.	Type of staircases	Width (In Mtrs)	No of staircases	Floors from	Floors to
1	Internal staircases	1.50	2	Ground	Terrace
2	External staircases	1.50	1	Ground	Terrace

7. Means of Escape Floor Wise Details

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per table 21 of NBC	Means of escape Provided
1	Ground	1277.86	EDUCATIONAL B-1 Schools up to senior secondary level	319.00	3.19	4.50
2	1st Floor	1277.86	EDUCATIONAL B-1 Schools up to senior secondary level	319.00	3.19	4.50

8. Floor Wise details of Fire Fighting Installations.

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Fire Alarm System	Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	7.00	2.00	0.00	0.00	0.00	0.00
2	1st Floor	7.00	2.00	0.00	0.00	0.00	0.00

9. Fire Fighting Installations as per Table 7 of NBC 2016:

Fire Fighting System.	Required As per NBC	Provided
Fire Extinguishers	14.00	26
First Aid Hose Reel	4.00	4
Terrace Tank over Respective Tower Terrace in Litres	10000.00	10000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm ²	450.00	450

10. The builder has provided the following additional Fire Safety Requirements as per NBC of India 2016 as per NBC part 4 of India 2016::

Sl. No	Fire safety Item
1.	Open spaces all around the building are Leveled and have hard open spaces for the operation of fire vehicles.
2.	The upper floors of the educational building are provided with exits for every travel distance of 30 meters (TYPE I & 2 constructions) as per table 5 under clause 4.4.2.1, 4.4.2.2 of Part IV of NBC 2016
3.	The width of all exit door ways has 01-00 meter for class rooms and 02-00 meters in respect of Assembly halls as per clause 8.1 of IS 14435:1997?
4.	The height of exit door ways has 02-00 meters and more, as per clause of 8.2 of IS 14435:1997?
5.	A minimum number of two separate exits are provided for each floor as per clause 6.2 of IS 14435:1997?
6.	The exits shall be remote from each other as practicable as per clause 6.2 of IS 14435:1997?
8.	The Location of Rooms of Preschool, Kindergarten, Class/Grade 1 student are provided at Ground Floor/level and Class/Grade II student at ground or First Floor only.

11) In view of the above and as per recommendations of the multistoried building inspection Committee, the No Objection Certificate for occupancy is issued to Multi Storied Building with

Sl No	As Builder	As occupant	As Security Personnel
1	-All the fire protection arrangements shall be maintained in good condition as seen during inspection. -Do's and Don't in case of fire shall be prominently displayed in entire building	All the escape/exit roots shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.


2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If Not, take all steps to isolate the area by closing doors and windows.

This No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison - A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
 Director General of State Disaster
 Response & Fire Services
 Telangana, Hyderabad

Copies to:

- i) The Management
- ii) Multistoried Building Inspection Committee

1/True copy

 Gazetted Headmaster
 Z.P.H.S. SOMARAM
 Mdt: Rajapet, Dist: Yadadri Bhuvanagiri